

# PORTABLE APPLIANCE TEST CERTIFICATE

Site: Musicology

Reference: MU

Appliance Identity Description	Location Serial Number	Test Date Next Test Date	Visual Check	Earth Bond Current Resistance	Insulation Resistance	Flash	Load kVA A	Leakage	Substitute Leakage	Touch Leakage	Continuity	Comments	Result
000000001 crossfire xp	studio	29/02/2020 28/02/2021	Pass	200.00 mA 0.00 OHM Pass	Skip	Skip	Skip	Skip	0.42 mA Pass	Skip	Skip		Pass
000000002 extension lead	studio	29/02/2020 28/02/2021	Pass	10.00 A 0.14 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000003 extension lead	studio	29/02/2020 28/02/2021	Pass	10.00 A 0.13 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000004 extension lead	studio	29/02/2020 28/02/2021	Pass	10.00 A 0.14 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000005 extension lead	studio	29/02/2020 28/02/2021	Pass	10.00 A 0.11 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000006 extension lead	studio	29/02/2020 28/02/2021	Pass	10.00 A 0.11 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000007 extension lead	studio	29/02/2020 28/02/2021	Pass	10.00 A 0.16 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000008 extension reel	studio	29/02/2020 28/02/2021	Pass	10.00 A 0.25 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000009 extension reel	studio	29/02/2020 28/02/2021	Pass	10.00 A 0.23 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000010 prismo 60	studio	29/02/2020 28/02/2021	Pass	200.00 mA 0.05 OHM Pass	Skip	Skip	Skip	Skip	0.07 mA Pass	Skip	Skip		Pass
000000011 prismo 60	studio	29/02/2020 28/02/2021	Pass	200.00 mA 0.14 OHM Pass	Skip	Skip	Skip	Skip	0.19 mA Pass	Skip	Skip		Pass
000000012 uv batten	studio	29/02/2020 28/02/2021	Pass	200.00 mA 0.10 OHM Pass	Skip	Skip	Skip	Skip	0.57 mA Pass	Skip	Skip		Pass
000000013 adj ultrabar	studio	29/02/2020 28/02/2021	Pass	200.00 mA 0.02 OHM Pass	Skip	Skip	Skip	Skip	0.28 mA Pass	Skip	Skip		Pass
000000014 iec lead	studio	29/02/2020 28/02/2021	Pass	10.00 A 0.14 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000015 optic 250	studio	29/02/2020 28/02/2021	Pass	200.00 mA 0.02 OHM Pass	Skip	Skip	Skip	Skip	0.52 mA Pass	Skip	Skip		Pass

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

# PORTABLE APPLIANCE TEST CERTIFICATE

Site: Musicology

Reference: MU

Appliance Identity Description	Location Serial Number	Test Date Next Test Date	Visual Check	Earth Bond Current Resistance	Insulation Resistance	Flash	Load kVA A	Leakage	Substitute Leakage	Touch Leakage	Continuity	Comments	Result
000000016 sensory 250	studio	29/02/2020 28/02/2021	Pass	200.00 mA 0.02 OHM Pass	Skip	Skip	Skip	Skip	0.57 mA Pass	Skip	Skip		Pass
000000017 sensory 250	studio	29/02/2020 28/02/2021	Pass	200.00 mA 0.17 OHM Pass	Skip	Skip	Skip	Skip	0.08 mA Pass	Skip	Skip		Pass
000000018 sensory 250	studio	29/02/2020 28/02/2021	Pass	200.00 mA 0.01 OHM Pass	Skip	Skip	Skip	Skip	0.59 mA Pass	Skip	Skip		Pass
000000019 decks	studio	29/02/2020 28/02/2021	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000020 chauvet dj barrel	studio	29/02/2020 28/02/2021	Pass	200.00 mA 0.02 OHM Pass	Skip	Skip	Skip	Skip	0.12 mA Pass	Skip	Skip		Pass
000000021 barrel light	studio	29/02/2020 28/02/2021	Pass	200.00 mA 0.03 OHM Pass	Skip	Skip	Skip	Skip	0.12 mA Pass	Skip	Skip		Pass
000000022 power strobe	studio	29/02/2020 28/02/2021	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000023 iec 3 way	studio	29/02/2020 28/02/2021	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000024 microphone	studio	29/02/2020 28/02/2021	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000025 yamaha speaker	studio	29/02/2020 28/02/2021	Pass	200.00 mA 0.03 OHM Pass	Skip	Skip	Skip	Skip	0.58 mA Pass	Skip	Skip		Pass
000000026 yamaha speaker	studio	29/02/2020 28/02/2021	Pass	200.00 mA 0.65 OHM Pass	Skip	Skip	Skip	Skip	0.55 mA Pass	Skip	Skip		Pass
000000027 speaker	studio	29/02/2020 28/02/2021	Pass	200.00 mA 0.43 OHM Pass	Skip	Skip	Skip	Skip	0.53 mA Pass	Skip	Skip		Pass
000000028 iec lead	studio	29/02/2020 28/02/2021	Pass	10.00 A 0.09 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000029 laptop	studio	29/02/2020 28/02/2021	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000030 iec t lead	studio	29/02/2020 28/02/2021	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass

Signature: \_\_\_\_\_

Date: \_\_\_\_\_