

PORTABLE APPLIANCE TEST CERTIFICATE

Site: Musicolgy

Reference: MU18

Appliance Identity Description	Location Serial Number	Test Date Next Test Date	Visual Check	Earth Bond Current Resistance	Insulation Resistance	Flash	Load kVA A	Leakage	Substitute Leakage	Touch Leakage	Continuity	Comments	Result
000000001 numark ndx200	studio	19/02/2018 19/02/2019	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000002 dj console rmx2	studio	19/02/2018 19/02/2019	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000003 light	studio	19/02/2018 19/02/2019	Pass	200.00 mA 0.74 OHM Pass	Skip	Skip	Skip	Skip	0.06 mA Pass	Skip	Skip		Pass
000000004 alto steath	studio	19/02/2018 19/02/2019	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000005 charger	studio	19/02/2018 19/02/2019	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000006 charger	studio	19/02/2018 19/02/2019	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000007 mic	studio	19/02/2018 19/02/2019	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000008 speaker	studio	19/02/2018 19/02/2019	Pass	200.00 mA 0.12 OHM Pass	Skip	Skip	Skip	Skip	0.52 mA Pass	Skip	Skip		Pass
000000009 speaker	studio	19/02/2018 19/02/2019	Pass	200.00 mA 0.00 OHM Pass	Skip	Skip	Skip	Skip	0.50 mA Pass	Skip	Skip		Pass
000000010 denon dj	studio	19/02/2018 19/02/2019	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000011 barrel 305irc	studio	19/02/2018 19/02/2019	Pass	200.00 mA 0.03 OHM Pass	Skip	Skip	Skip	Skip	0.11 mA Pass	Skip	Skip		Pass
000000012 extension lead	studio	19/02/2018 19/02/2019	Pass	10.00 A 0.25 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000013 extension lead	studio	19/02/2018 19/02/2019	Pass	10.00 A 0.25 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000014 barrel 305irc	studio	19/02/2018 19/02/2019	Pass	200.00 mA 0.03 OHM Pass	Skip	Skip	Skip	Skip	0.12 mA Pass	Skip	Skip		Pass
000000015 strobe	studio	19/02/2018 19/02/2019	Pass	200.00 mA 0.31 OHM Pass	Skip	Skip	Skip	Skip	0.05 mA Pass	Skip	Skip		Pass

Signature: _____

Date: _____

PORTABLE APPLIANCE TEST CERTIFICATE

Site: Musicolgy

Reference: MU18

Appliance Identity Description	Location Serial Number	Test Date Next Test Date	Visual Check	Earth Bond Current Resistance	Insulation Resistance	Flash	Load kVA A	Leakage	Substitute Leakage	Touch Leakage	Continuity	Comments	Result
000000016 extension lead	studio	19/02/2018 19/02/2019	Pass	10.00 A 0.14 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000017 laser light	studio	19/02/2018 19/02/2019	Pass	200.00 mA 0.03 OHM Pass	Skip	Skip	Skip	Skip	0.13 mA Pass	Skip	Skip		Pass
000000018 mic	studio	19/02/2018 19/02/2019	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000019 prismo 60	studio	19/02/2018 19/02/2019	Pass	200.00 mA 0.76 OHM Pass	Skip	Skip	Skip	Skip	0.25 mA Pass	Skip	Skip		Pass
000000020 led light	studio	19/02/2018 19/02/2019	Pass	200.00 mA 0.15 OHM Pass	Skip	Skip	Skip	Skip	0.58 mA Pass	Skip	Skip		Pass
000000021 led light	studio	19/02/2018 19/02/2019	Pass	200.00 mA 0.08 OHM Pass	Skip	Skip	Skip	Skip	0.57 mA Pass	Skip	Skip		Pass
000000022 spectra batten	studio	19/02/2018 19/02/2019	Pass	200.00 mA 0.08 OHM Pass	Skip	Skip	Skip	Skip	0.58 mA Pass	Skip	Skip		Pass
000000023 ultra bar 12	studio	19/02/2018 19/02/2019	Pass	200.00 mA 0.27 OHM Pass	Skip	Skip	Skip	Skip	0.25 mA Pass	Skip	Skip		Pass
000000024 laser light	studio	19/02/2018 19/02/2019	Pass	200.00 mA 0.09 OHM Pass	Skip	Skip	Skip	Skip	0.65 mA Pass	Skip	Skip		Pass
000000025 smoke machine	studio	19/02/2018 19/02/2019	Pass	200.00 mA 0.67 OHM Pass	Skip	Skip	Skip	Skip	0.09 mA Pass	Skip	Skip		Pass
000000026 led light	studio	19/02/2018 19/02/2019	Pass	200.00 mA 0.13 OHM Pass	Skip	Skip	Skip	Skip	0.06 mA Pass	Skip	Skip		Pass
000000027 solar 250	studio	19/02/2018 19/02/2019	Pass	200.00 mA 0.27 OHM Pass	Skip	Skip	Skip	Skip	0.07 mA Pass	Skip	Skip		Pass
000000028 laptop	studio	19/02/2018 19/02/2019	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass

Signature: _____

Date: _____