

PORTABLE APPLIANCE TEST CERTIFICATE

Site: Musicology

Reference: MU19

Appliance Identity Description	Location Serial Number	Test Date Next Test Date	Visual Check	Earth Bond Current Resistance	Insulation Resistance	Flash	Load kVA A	Leakage	Substitute Leakage	Touch Leakage	Continuity	Comments	Result
000000001 speaker	studio	02/03/2019 02/03/2020	Pass	200.00 mA 0.18 OHM Pass	Skip	Skip	Skip	Skip	0.56 mA Pass	Skip	Skip		Pass
000000002 speaker	studio	02/03/2019 02/03/2020	Pass	200.00 mA 0.89 OHM Pass	Skip	Skip	Skip	Skip	0.52 mA Pass	Skip	Skip		Pass
000000003 speaker	studio	02/03/2019 02/03/2020	Pass	200.00 mA 0.24 OHM Pass	Skip	Skip	Skip	Skip	0.49 mA Pass	Skip	Skip		Pass
000000004 light bar	studio	02/03/2019 02/03/2020	Pass	200.00 mA 0.13 OHM Pass	Skip	Skip	Skip	Skip	0.22 mA Pass	Skip	Skip		Pass
000000005 extension lead	studio	02/03/2019 02/03/2020	Pass	Skip	Skip	Skip	Skip	Skip	Skip	Skip	Skip	surge protected	Pass
000000006 extension lead	studio	02/03/2019 02/03/2020	Pass	10.00 A 0.20 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000007 extension lead	studio	02/03/2019 02/03/2020	Pass	10.00 A 0.19 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000008 extension lead	studio	02/03/2019 02/03/2020	Pass	10.00 A 0.18 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000009 strobe master	studio	02/03/2019 02/03/2020	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000010 power strobe	studio	02/03/2019 02/03/2020	Pass	200.00 mA 0.41 OHM Pass	Skip	Skip	Skip	Skip	0.03 mA Pass	Skip	Skip		Pass
000000011 extension reel	studio	02/03/2019 02/03/2020	Pass	10.00 A 0.29 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000012 extension lead	studio	02/03/2019 02/03/2020	Pass	10.00 A 0.29 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000013 microphone power	studio	02/03/2019 02/03/2020	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000014 mixer	studio	02/03/2019 02/03/2020	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000015 barrel light	studio	02/03/2019 02/03/2020	Pass	200.00 mA 0.18 OHM Pass	Skip	Skip	Skip	Skip	0.12 mA Pass	Skip	Skip		Pass

Signature: _____

Date: _____

PORTABLE APPLIANCE TEST CERTIFICATE

Site: Musicology

Reference: MU19

Appliance Identity Description	Location Serial Number	Test Date Next Test Date	Visual Check	Earth Bond Current Resistance	Insulation Resistance	Flash	Load kVA A	Leakage	Substitute Leakage	Touch Leakage	Continuity	Comments	Result
000000016 iec lead	studio	02/03/2019 02/03/2020	Pass	10.00 A 0.26 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000017 barrel light	studio	02/03/2019 02/03/2020	Pass	10.00 A 0.73 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000018 asbtract xp5	studio	02/03/2019 02/03/2020	Pass	200.00 mA 0.11 OHM Pass	Skip	Skip	Skip	Skip	0.05 mA Pass	Skip	Skip		Pass
000000019 solar 250	studio	02/03/2019 02/03/2020	Pass	200.00 mA 0.03 OHM Pass	Skip	Skip	Skip	Skip	0.05 mA Pass	Skip	Skip		Pass
000000020 solar led	studio	02/03/2019 02/03/2020	Pass	200.00 mA 0.05 OHM Pass	Skip	Skip	Skip	Skip	0.05 mA Pass	Skip	Skip		Pass
000000021 solar led	studio	02/03/2019 02/03/2020	Pass	200.00 mA 0.03 OHM Pass	Skip	Skip	Skip	Skip	0.05 mA Pass	Skip	Skip		Pass
000000022 solar led	studio	02/03/2019 02/03/2020	Pass	200.00 mA 0.15 OHM Pass	Skip	Skip	Skip	Skip	0.04 mA Pass	Skip	Skip		Pass
000000023 iec lead	studio	02/03/2019 02/03/2020	Pass	10.00 A 0.16 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000024 laptop	studio	02/03/2019 02/03/2020	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass

Signature: _____

Date: _____